



## AHERN – ADDITIONS AND ALTERATIONS

SULLIVAN COUNTY COMPLEX  
5 NURSING HOME DRIVE  
UNITY, NH 03743

# ADDENDUM #2 REQUEST FOR PROPOSAL CONSTRUCTION SERVICES AHERN BLDG – ADDITIONS AND ALTERATIONS

ISSUE DATE: JUNE 5, 2019

PROPOSALS WILL BE RECEIVED UNTIL  
Tuesday, June 11, 2019 at 2:00 P.M.

The Request for Qualifications/Proposal (RFP) is modified as set forth in this Addendum.

The original RFP Documents, and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the RFP. Respondent shall take this Addendum into consideration when preparing and submitting its Proposal. Respondent shall acknowledge in their Response that Addendum #1 has been received and reviewed.

The Addendum does not modify the Proposal due date and time.

### RFQ/RFP ADDITIONS, DELETIONS, OR CHANGES:

1. Add Section 06 1500 Wood Decking and updated Table of Contents to the Project Documents.
2. Delete Section 09 5100 Acoustical Ceilings from the Project Documents.

### RFP QUESTION:

**Question: Does the Air Conditioning system Alternate need to be design for 300 people as listed on Drawing A2.**

---

No, the air condition system should be designed for approximately 50 people with enough capacity to account for personal laptops and projectors used during business meetings. The County enforces the 50-person load occupant